






ECO No	DESCRIPTION	REV BY	DATE




**SIDE VIEW
(PANELS REMOVED)**



CUSTOMER CONNECTION DETAIL VIEW AT REACTOR

- NOTES:**
- 1. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS**
 - 2. WIRE RANGE: 4-14 AWG.**
 - 3. CUSTOMER DOES NOT CONNECT TO U4, V4, & W4 LOCATED ON THE REACTOR TERMINAL BLOCK.**

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION			
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION MATRIX AP 14A 240V 60Hz FILTER, NEMA 1/2 ENCL			
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: $\pm 1^\circ$ 1 PLACE .X: $\pm .1$ [2.5] 2 PLACE .XX: $\pm .03$ [0.76] 3 PLACE .XXX: $\pm .010$ [0.254]		DRAWN		DATE			
		KV		08/08/18			
		CHECKED		DATE			
		WF		10/09/18			
		APPROVED		DATE			
		JG		10/10/18			
				SIZE	DWG No.	REV	
				D	CD MAPG0014A	00	
				SCALE	1:3	SHEET 1 OF 1	