

APPROX. WEIGHT  
(LBS)  
77

D

C

B

A

FRONT VIEW  
(PANELS REMOVED)

SIDE VIEW  
(PANELS REMOVED)

BOTTOM VIEW


TOP VIEW  
(PANEL REMOVED)

CUSTOMER CONNECTION  
DETAIL VIEW AT REACTOR

SEE NOTE 1, 2, & 3

NOTES:

1. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LBS
2. WIRE RANGE: 4-14 AWG.
3. CUSTOMER DOES NOT CONNECT TO U4, V4, & W4 LOCATED ON THE REACTOR TERMINAL BLOCK.

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2		MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION			
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION				DESCRIPTION			
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:  ANGLES: ± 1 °  1 PLACE .X: ± .1 [2.5]  2 PLACE .XX: ± .03 [0.76]  3 PLACE .XXX: ± .010 [0.254]		  N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200		MATRIX AP 11A 240V 60Hz FILTER, NEMA 3R ENCL			
		DRAWN	DATE	SIZE	DWG No.	REV	
		KV	09/04/18				
		CHECKED	DATE				
		WF	10/09/18	D	CD MAPW0011A	00	
		APPROVED	DATE				
		JG	10/10/18	SCALE	1:3	SHEET 1 OF 1	