

RF3-0070-6

AKA

n/a

Device

rfi filter

Current

70A 40°C

Earthing

M8x23 stud 6Nm

Enclosure

aluminium 1.2mm

Loss

6.4W/ph

Leakage

39.7mA operating

Mass

4kg

Mounting

M6x4

PCB

FR4 AVLV2 VW-1 600V 105°C IIIa

Potting

air

Power

72.7kW(16.8kW)

Protection

IP20

Resistance

1.3mR/ph

Residual

399V 5s

SCCR

200kA

Style

terminal filter

Terminal

screw 2.5-35mm² 4.5Nm 18mm

Varistor

n/a

Supply

3P 600V 50/60Hz

Voltage

600V (600V IT) max

Withstand

3200Vdc 60s

Altitude

2000m w/out derating

Bonding

25A 50/60Hz

Class

class I

Environment

-25/+85/21

Flammability

UL94 V-2 min

Humidity

93% RH non-condensing

Insulation

500Vdc ≥3.5MR

Material

group II Ib

MTBF

22yrs (MIL-HDBK-217F)

Overload

135% 2hrs 150% 60s

Overvoltage

category II

Packaging

ASTM D7386

Pollution

degree II

Shock

15g 11mS

Spacing

≥50mm gap

Vibration

5-55Hz 350um 55-500Hz 2G

EU

CE EN60939

US

uR UL1283

CAN

cUR CSA22.2

OTHER

n/a

4

3

2

1

TOP VIEW

12.28
[312]

3.66
[93]

5.71
[145.16]

SIDE VIEW

7.52
[191]

FRONT VIEW

12.28
[312]

3.66
[93]

11.73
[298]

3.11
[79]

0.28
[7]

0.31
[7.75]

0.28 [7] THRU
2 PLACES

0.28 [7] X .39 [10]
SLOT, 2 PLACES

BOTTOM VIEW

PRODUCT LABEL

RFI/EMI FILTER 70A 600V

4

3

2

1

CONFIDENTIAL AND PROPRIETARY INFORMATION

THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION

DESCRIPTION

RFI/EMI FILTER 70A 600V

SIZE B

DWG No. RF3-0070-6

REV 00

SCALE 1:5

SHEET 1 OF 1

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2

CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES [MM]
TOLERANCES ARE:
ANGLES: ± 1 °
1 PLACE .X: ± .1 [2.5]
2 PLACE .XX: ± .03 [0.76]
3 PLACE .XXX: ± .010 [0.254]

MTE

POWER QUALITY. SOLVED.

N83 W13330 Leon Road
Menomonee Falls, WI 53051 USA
800.455-4683
262.253.8200

MATERIAL

DRAWN CH

DATE 12/19/18

CHECKED CH

DATE 12/19/18

APPROVED AK

DATE 01/02/19