RF3-0330-6	
AKA	n/a
Device	rfi filter
Current	330A 50°C
Earthing	M10x25 stud 25Nm
Enclosure	aluminium 2mm
Loss	9W/ph
Leakage	45.6mA operating
Mass	14.2kg
Mounting	M10x4 30Nm
PCB	FR4 AVLV2 VW-1 600V 105°C IIIa
Potting	resin
Power	436kW(100.8kW)
Protection	IP00
Resistance	51uR/ph
Residual	484V 5s
SCCR	200kA
Style	busbar filter
Terminal	bar 25.4x6.3mm M10x20mm 30Nm
Varistor	n/a
Supply	3P 600V 50/60Hz
Voltage	600V (600V IT) max
Withstand	3200Vdc 60s
Altitude	2000m w/out derating
Bonding	25A 50/60Hz
Class	class I
Environment	-25/+85/21
Flammability	UL94 V-2 min
Humidity	93% RH non-condensing
Insulation	500Vdc ≥3.5MR
Material	group IIIb
MTBF	22yrs (MIL-HDBK-217F)
Overload	135% 2hrs 150% 60s
Overvoltage	category II
Packaging	ASTM D7386
Pollution	degree II
Shock	15g 11mS
Spacing	≥50mm gap
Vibration	5-55Hz 350um 55-500Hz 2G
EU	CE EN60939
US	uR UL1283
CAN	cUR CSA22.2
OTHER	n/a



TOP VIEW





SIDE VIEW



FRONT VIEW



BOTTOM VIEW

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2

CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:

ANGLES: ± 1 °

1 PLACE .X: ± .1 [2.5]

2 PLACE .XX: ± .03 [0.76]

3 PLACE .XXX: ± .010 [0.254]

MTE
POWER QUALITY. SOLVED.
N83 W13330 Leon Road
Menomonee Falls, WI 53051 USA
800.455-4683
262.253.8200

MATERIAL

DRAWN	CH	DATE	12/19/18
CHECKED	CH	DATE	12/19/18
APPROVED	AK	DATE	01/02/19

CONFIDENTIAL AND PROPRIETARY INFORMATION
THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION

DESCRIPTION

RFI/EMI FILTER 330A 600V

SIZE	DWG No.	REV
B	RF3-0330-6	00

SCALE 1:5 SHEET 1 OF 1