




WEIGHT (LBS)	INDUCTANCE	LOSS (WATTS)
49	.115mH	224



ECO No	DESCRIPTION	REV BY	DATE
M11127	UPDATED TO REFLECT REMOVAL OF PAPER-338	SM	08/31/18




DETAIL A
6 PLACES



VIEW A-A



DETAIL B
2 PLACES



<p>THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU (EUROPEAN UNION) DIRECTIVE RoHS2</p> <p>CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION</p>		<p>MATERIAL</p>		<p>CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION</p>	
<p>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE:</p> <p>ANGLES: ± 1 °</p> <p>1 PLACE .X: ± .1 [2.5]</p> <p>2 PLACE .XX: ± .03 [0.76]</p> <p>3 PLACE .XXX: ± .010 [0.254]</p>		<p>MTE POWER QUALITY. SOLVED.</p> <p>N83 W13330 Leon Road Menomonee Falls, WI 53051 USA 800.455.4683 262.253.8200</p>		<p>DESCRIPTION</p> <p>LINE REACTOR (200A, .115mH)</p>	
<p>DRAWN RKT</p> <p>CHECKED SM</p> <p>APPROVED AK</p>		<p>DATE 03/31/09</p> <p>DATE 08/31/18</p> <p>DATE 09/05/18</p>		<p>SIZE D</p> <p>SCALE 5:6</p>	
		<p>DATE 03/31/09</p> <p>DATE 08/31/18</p> <p>DATE 09/05/18</p>		<p>DWG No. CD RLW-020003</p> <p>REV 04</p> <p>SHEET 1 OF 1</p>	