





APPROX. WEIGHT
(LBS)
32




FRONT VIEW
(PANELS REMOVED)




SIDE VIEW



BOTTOM VIEW



TOP VIEW
(PANELS REMOVED)



DETAIL A
CUSTOMER CONNECTION
DETAIL VIEW

NOTES:

1. TERMINAL WIRE SIZE: 4-14 AWG.
2. TERMINAL SCREW TIGHTENING TORQUE: 16 IN/LB.

THE COMPONENT, PART OR ASSEMBLY DESCRIBED IN THIS DOCUMENT MUST COMPLY WITH THE EU(EUROPEAN UNION) DIRECTIVE RoHS2			MATERIAL		CONFIDENTIAL AND PROPRIETARY INFORMATION THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF MTE CORPORATION AND MAY NOT BE USED, COPIED OR DISCLOSED TO OTHERS EXCEPT WITH THE AUTHORIZED WRITTEN PERMISSION OF MTE CORPORATION		
CONTAINS <0.1% OF ANY SVHC BY WEIGHT PER REACH REGULATION					DESCRIPTION		
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES [MM] TOLERANCES ARE: ANGLES: ± 1 ° 1 PLACE .X: ± .1 [2.5] 2 PLACE .XX: ± .03 [0.76] 3 PLACE .XXX: ± .010 [0.254]			DRAWN JT		DATE 02/20/17		
			CHECKED JT		DATE 02/20/17		
			APPROVED TL		DATE 07/05/18		
			SIZE D		DWG No. CD SWGG0009E		
			SCALE 1:2		REV 01		
					SHEET 1 OF 1		

MTE
POWER QUALITY. SOLVED.

N83 W13330 Leon Road
Menomonee Falls, WI 53051 USA
800.455.4683
262.253.8200